

CSO Summary Report

For overflows between: 1/1/13 And 12/31/13

<i>Overflow ID</i>	<i>Service Area / Municipality</i>	<i>Facility</i>	<i>Date Began</i>	<i>Date Ended</i>	<i>Duration (hours)</i>	<i>Volume Gallons</i>	<i>Receiving Water</i>	<i>Cause</i>	<i>POTW</i>
288	City of Syracuse	CSO 033 Dickerson Street	02/19/2013	02/19/2013	1.25		Onondaga Creek	City of Syracuse water main break at the corner of Walton and Fayette overwhelmed City owned sewers and County owned Main Intercepting Sewer.	Metropolitan Syracuse
287	City of Syracuse	CSO 029 Walton Street	02/19/2013	02/19/2013	6.17		Onondaga Creek	City of Syracuse water main break at the corner of Walton and Fayette overwhelmed City owned sewers and County owned Main Intercepting Sewer.	Metropolitan Syracuse
309	City of Syracuse	CSO 078 Bellevue Avenue	08/21/2013	08/21/2013	0.67	200	Harbor Brook	Rags restricting flow in regulator pipe.	Metropolitan Syracuse
312	City of Syracuse	Manholes	09/01/2013	09/01/2013	0.00		Harbor Brook	Heavy rainfall with intensity of 0.88 in/hr and potential surcharge condition caused by temporary bulk head installed in the sewer line.	Metropolitan Syracuse
317	City of Syracuse	County owned CSO 030 Regulator	10/30/2013	10/30/2013	0.75	600	Onondaga Creek	Contractor performing emergency repair for the County, was driving sheet piling preparing to replace the regulator pipe from the Franklin Street Trunk Sewer to the Main Intercepting Sewer (M.I.S.). Vibrations from the sheet piling operation likely caused the regulator pipe to shift and become restricted.	Metropolitan Syracuse