

Library Reference 4.3

Headworks Bypasses (Outfall 001), 2011.

Start Date	Duration (Hours)	Million Gallons
4/25/11	22.70	5.236
9/7/11	1.52	0.139
Total	24.22	5.38

4/25/11 - Mechanical failure: electrical failure of primary cone valves.