

Library Reference 4.3.2

Metro effluent concentrations for Ammonia-N, 2009, with SPDES limits.

SPDES Limit	Effective Date	2009 Results (average)
<i>Stage 1:</i> 8,700 ppd (7/1-9/30) 13,100 ppd (10/1-6/30)	January 1998	0.22 mg/l (6/1/09-10/31/09)
<i>Stage 2:</i> 2 mg/l (6/1-10/31) 4 mg/l (11/1-5/31)	May 2004	0.40 mg/l (11/1/08 -5/31/09)
<i>Stage 3:</i> 1.2 mg/l (6/1-10/31) 2.4 mg/l (11/1-5/31)	Dec. 2012 (Met Feb. 2004)	